



**ENVIRONMENT
AGENCY**

Variation Notice with introductory note

Pollution Prevention and Control Regulations 2000

**Dudley Energy from
Waste Facility
MES Environmental Ltd
Lister Road
Dudley
West Midlands
DY2 8JT**

Variation Notice number

UP3638MD

Permit number

AP3435SD

Introductory note

This introductory note does not form a part of the permit.

The following notice is issued under Regulation 17 of The Pollution Prevention and Control (England and Wales) Regulations 2000 (S.I.2000 No. 1973 (as amended) (the Regulations) to vary the conditions of a permit issued under the Regulations to operate an installation. The notice comprises Schedule 1 containing conditions to be deleted, Schedule 2 conditions to be amended and Schedule 3 conditions to be added.

Brief description of the changes introduced by this variation notice.

This Agency initiated minor variation changes the emission limit value and the method of demonstrating compliance for carbon monoxide (CO). The Waste Incineration Directive (WID) allows compliance with CO continuous emissions monitors to be demonstrated by 100% compliance with the 100 mg.m⁻³ limit for ½ hourly averages or, alternatively, 95% compliance with a 150 mg.m⁻³ limit for 10-minute averages. When the permit was issued in December 2005, as a policy, we put the 100% compliance figure in the permit. However, the Operator has recently produced data to show that the alternative 95% compliance regime is more appropriate for this site and they shall now demonstrate compliance with this method.

Status Log

Status Log of the permit		
Detail	Date	Response Date
Application AP3435SD	Received 11/03/2005	
Response to request for information	Request dated 10/05/2005	Response dated 11/08/2005
Permit determined	01/12/2005	
Variation notice UP3638MD issued	14/11/2006	

SCHEDULE 1 - CONDITIONS TO BE DELETED

1.1 None

SCHEDULE 2 - CONDITIONS TO BE AMENDED

2.1 The following condition shall be amended as follows:

2.2.1.3 The limits for emissions to air for the parameters and emission points set out in Table 2.2.2 shall not be exceeded except during a period of abnormal operation. During a period of abnormal operation, the limits for emissions to air for the parameters and emission points set out in Table 2.2.2 (a) shall not be exceeded.

Table 2.2.2 : Emission limits to air and monitoring during normal operation

Emission reference	point	Parameter	Limit (including Reference Period) ¹	Monitoring frequency	Monitoring method
A1,A2		Particulate matter	30 mg/m ³ ½-hr average	Continuous measurement	BS EN 13284-68
A1,A2		Particulate matter	10 mg/m ³ daily average	Continuous measurement	BS EN 13284-68
A1,A2		Particulate matter	20 mg/m ³ periodic over minimum 1-hour period	Bi-annual	BS EN 13284-68
A1,A2		Total Organic Carbon (TOC)	20 mg/m ³ ½-hr average	Continuous measurement	BS EN 12619-8
A1,A2		Total Organic Carbon (TOC)	10 mg/m ³ daily average	Continuous measurement	BS EN 12619-8
A1,A2		Total Organic Carbon (TOC)	20 mg/m ³ periodic over minimum 1-hour period	Bi-annual	BS EN 12619-8
A1,A2		Hydrogen chloride	60 mg/m ³ ½-hr average	Continuous measurement	MCERTS certified instruments ⁷⁹
A1,A2		Hydrogen chloride	10 mg/m ³ daily average	Continuous measurement	MCERTS certified instruments ⁷⁹
A1,A2		Hydrogen chloride	30 mg/m ³	Bi-annual	BS EN 1911

Table 2.2.2 : Emission limits to air and monitoring during normal operation

Emission reference	point	Parameter	Limit (including Reference Period) ¹	Monitoring frequency	Monitoring method
			periodic over minimum 1-hour period		
A1,A2		Hydrogen fluoride	2 mg/m ³ periodic over minimum 1-hour period	Quarterly	USEPA Method 26/26A
A1,A2		Carbon monoxide	At least 95% of all measurements shall not exceed 150 mg/m ³ in any 24-hour period 10-minute average	Continuous measurement	ISO 12039 ^{4,8}
A1,A2		Carbon monoxide	50 mg/m ³ daily average	Continuous measurement	ISO 12039 ^{4,8}
A1,A2		Carbon monoxide	100 mg/m ³ periodic over minimum 4 hour period, data to be reported as 10-minute averages	Bi-annual	ISO 12039
A1,A2		Sulphur dioxide	200 mg/m ³ ½-hr average	Continuous measurement	BS 6069-4.4 ⁵
A1,A2		Sulphur dioxide	50 mg/m ³ daily average	Continuous measurement	BS 6069-4.4 ⁵
A1,A2		Sulphur dioxide	100 mg/m ³ periodic over minimum 4 hour period, data to be reported as ½ hour averages	Bi-annual	BS 6069-4.1 c alternative method if agreed in writ with the Agen
A1,A2		Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	400 mg/m ³ ½-hr average	Continuous measurement	ISO 10849 ^{5,8}
A1,A2		Oxides of nitrogen (NO and NO ₂ expressed as	200 mg/m ³ daily average	Continuous measurement	ISO 10849 ^{5,8}

Superseded or Partially Superseded Licences/Authorisations/Consents relating to this installation

Holder	Reference Number	Date of Issue	Fully or Partially Superseded
---------------	-------------------------	----------------------	--------------------------------------

MES Environmental Ltd	AX7571	14/07/1997	Fully
-----------------------	--------	------------	-------

End of introductory Note

Variation Notice

Pollution Prevention and Control
(England and Wales) Regulations 2000



**ENVIRONMENT
AGENCY**

Variation Notice

Permit number (The Permit)

AP3435SD

Variation number

UP3638MD

The Environment Agency in exercise of its powers under Regulation 17 of the Pollution Prevention and Control (England and Wales) Regulations 2000 (S.I. 2000 No. 1973) (as amended), hereby varies the permit held by you **MES Environmental Ltd** ("the Operator"),

whose Registered Office (or Principle Office) is
**Crown Street,
Wolverhampton,
West Midlands, WV1 1QB**

Company registration number 2826294

to operate the installation at
**Dudley Energy from Waste Facility, Lister Road,
Dudley,
West Midlands, DY2 8JT.**

to the extent set out in Schedules 1 to 3 of this variation notice.

This notice shall take effect from 14 November 2006.

Signed

RA Wynne

Authorised to sign on behalf of the Environment Agency

Date

14th November 2006

Table 2.2.2 : Emission limits to air and monitoring during normal operation

Emission reference	point	Parameter	Limit (including Reference Period) ¹	Monitoring frequency	Monitoring method
		NO ₂)			
A1,A2		Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	350 mg/m ³ periodic over minimum 4 hour period, data to be reported as ½-hour averages	Bi-annual	ISO 10849 or BS ISO 11564
A1,A2		Cadmium & thallium and their compounds (total) ²	0.05 mg/m ³ periodic over minimum 30 minute, maximum 8 hour period	Quarterly	BS EN 14385
A1,A2		Mercury and its compounds ²	0.05 mg/m ³ periodic over minimum 30 minute, maximum 8 hour period	Quarterly	BS EN 13211
A1,A2		Sb, As, Pb, Cr, Co, Cu, Mn, Ni and V and their compounds (total) ²	0.5 mg/m ³ periodic over minimum 30 minute, maximum 8 hour period	Quarterly	BS EN 14385
A1,A2		Dioxins / furans (I-TEQ)	0.1 ng/m ³ periodic over minimum 6 hours, maximum 8 hour period ³	Bi-annual	BS EN 1948

Note 1: See Section 6 for reference conditions

Note 2: Metals include gaseous, vapour and solid phases as well as their compounds (expressed as the metal or the sum of the metals as specified). Sb, As, Pb, Cr, Co, Cu, Mn, Ni and V mean antimony, arsenic, lead, chromium, cobalt, copper, manganese, nickel and vanadium respectively.

Note 3: The I-TEQ sum of the equivalence factors to be reported as a range based on: All congeners less than the detection limit assumed to be zero as a minimum, and all congeners less than the detection limit assumed to be at the detection limit as a maximum.

Note 4: The Continuous Emission Monitors used shall be such that the values of the 95% confidence intervals of a single measured result at the daily emission limit value shall not exceed 10%. Valid 10-minute average values shall be determined within the effective operating time (excluding the start-up and shut-down periods) from the measured values after having subtracted this value of the confidence interval (10%). Where it is necessary to calibrate or maintain the monitor and this means that data is not available for a complete 10-minute period, the 10-minute average shall nonetheless be considered valid if measurements are available for a minimum of 7 minutes during the 10-minute period. (The number of 10-minute averages so validated shall not exceed 25 per day). Daily average values shall be determined as the average of all the valid 10-minute average values within a calendar day. The daily average value will be considered valid if no more than 15 10-minute average values in any day have been determined not to be valid. No more than ten daily average values per year shall be determined not to be valid.

Note 5: The Continuous Emission Monitors used shall be such that the values of the 95% confidence intervals of a single measured result at the daily emission limit value shall not exceed 20%. Valid half-hourly average values shall be determined within the effective operating time (excluding the start-up and shut-down periods) from the measured values after having subtracted this value of the confidence interval (20%). Where it is necessary to calibrate or maintain the monitor and this means that data is not available for a complete half-hour period, the half-hourly average shall nonetheless be considered valid if measurements are available for a minimum of 20 minutes during the half-hour period. (The number of half-hourly averages so validated shall not exceed 8 per day). Daily average values shall be determined as the average of all the valid half-hourly average values within a calendar day. The daily average value will be considered valid if no more than five half-hourly average values in any day have been determined not to be valid. No more than ten daily average values per year shall be determined not to be valid.

Note 6: As Note 5, except that the value of the confidence interval is 30% in place of 20%.

Note 7: As Note 5, except that the value of the confidence interval is 40% in place of 20%.

Note 8: MCERTS certification to the appropriate ranges and determinands is a demonstration of compliance to the applicable standards.

Note 9: The CEM shall be able to measure instantaneous values over the ranges that are to be expected during all operating conditions.

Table 2.2.2 (a) : Emission limits to air and monitoring during abnormal operating conditions

Emission reference	point	Parameter	Limit (Including Reference Period) ¹	Monitoring frequency	Monitoring method
A1, A2		Particulate matter	150 mg/m ³ ½-hr average	Continuous measurement	BS EN 13824-2 ⁴² during abatement plant failure during failure of the continuous emission monitor
A1, A2		Total Organic Carbon (TOC)	20 mg/m ³ ½-hr average	Continuous measurement	BS EN 12619 ⁴² during abatement plant failure

during failure of the
continuous emission
monitor

A1, A2	Carbon monoxide	At least 95% of all measure- ments shall not exceed 150 mg/m ³ in any 24-hour period 10-minute average	Continuous measurement	ISO 12039 ^{4,3} during abatement plant failure o during failure of the continuous emission monitor
--------	--------------------	---	---------------------------	---

Note 1: See Section 6 for reference conditions

Note 2: The Continuous Emission Monitors used shall be such that the values of the 95% confidence intervals of a single measured result at the daily emission limit value shall not exceed 30%. Valid half-hourly average values shall be determined within the effective operating time (excluding the start-up and shut-down periods if no waste is being incinerated) from the measured values after having subtracted this value of the confidence interval (30%). Where it is necessary to calibrate or maintain the monitor and this means that data is not available for a complete half-hour period, the half-hourly average shall nonetheless be considered valid if measurements are available for a minimum of 20 minutes during the half-hour period. (The number of half-hourly averages so validated shall not exceed 8 per day).

Note 3: The Continuous Emission Monitors used shall be such that the values of the 95% confidence intervals of a single measured result at the daily emission limit value shall not exceed 10%. Valid 10-minute average values shall be determined within the effective operating time (excluding the start-up and shut-down periods if no waste is being incinerated) from the measured values after having subtracted this value of the confidence interval (10%). Where it is necessary to calibrate or maintain the monitor and this means that data is not available for a complete 10-minute period, the 10 minute average shall nonetheless be considered valid if measurements are available for a minimum of 7 minutes during the 10-minute period. (The number of 10-minute averages so validated shall not exceed 25 per day).

Note 4: MCERTS certification to the appropriate ranges and determinands is a demonstration of compliance to the applicable standards.

SCHEDULE 3 - CONDITIONS TO BE ADDED

3.1 None

Permit with introductory note

Pollution Prevention and Control (England & Wales) Regulations 2000

Woodhouse Fields Poultry Unit

**Mr J Benbow
Woodhouse Fields
Bourton
Much Wenlock
Shropshire
TF13 6QN**

Permit number

TP3736MW

Woodhouse Fields Poultry Unit Permit Number TP3736MW

Introductory note

This introductory note does not form a part of the permit

The main features of the installation are as follows:-

The installation covers an area of approximately 2.25 hectares situated on level ground 1.3 kilometres south east of Brouton in the county of Shropshire. The installation is operated by Mr Jonathan Benbow for the intensive rearing of broiler chickens with a capacity for 210,000 poultry places in 7 purpose built poultry houses. The installation also has an approved (Animal By-Products Regulations) incinerator which the operator uses for the disposal of dead poultry.

The predominant surrounding land use is grazing and arable farming. There is a disused airfield to the south east of the site which is used for farming and small-scale light industry use. The installation is situated 520 metres east of the flood plain of the River Corve.

There are no other PPC permits associated with the installation. The only emissions from the installation will be fugitive in the form of ammonia from the broiler units, surface water from the buildings and installation infrastructure and exhaust emissions from the Animal By-Products approved Carcass Incinerator.

There are three Sites of Special Scientific Interest located within 5km of the installation. The nearest is Wenlock Edge which is 3,033m from the installation. There are no European habitat sites located within 10km of the installation.

Status Log of the permit

Detail	Date	Response Date
Application TP3736MW	Duly made 01/12/06	
Permit determined	30/10/07	

End of Introductory Note



**ENVIRONMENT
AGENCY**

Variation Notice with introductory note

Pollution Prevention and Control Regulations 2000

**Dudley Energy from
Waste Facility
MES Environmental Ltd
Lister Road
Dudley
West Midlands
DY2 8JT**

Variation Notice number

UP3638MD

Permit number

AP3435SD

Introductory note

This introductory note does not form a part of the permit.

The following notice is issued under Regulation 17 of The Pollution Prevention and Control (England and Wales) Regulations 2000 (S.I.2000 No. 1973 (as amended) (the Regulations) to vary the conditions of a permit issued under the Regulations to operate an installation. The notice comprises Schedule 1 containing conditions to be deleted, Schedule 2 conditions to be amended and Schedule 3 conditions to be added.

Brief description of the changes introduced by this variation notice.

This Agency initiated minor variation changes the emission limit value and the method of demonstrating compliance for carbon monoxide (CO). The Waste Incineration Directive (WID) allows compliance with CO continuous emissions monitors to be demonstrated by 100% compliance with the 100 mg.m⁻³ limit for ½ hourly averages or, alternatively, 95% compliance with a 150 mg.m⁻³ limit for 10-minute averages. When the permit was issued in December 2005, as a policy, we put the 100% compliance figure in the permit. However, the Operator has recently produced data to show that the alternative 95% compliance regime is more appropriate for this site and they shall now demonstrate compliance with this method.

Status Log

Status Log of the permit

Detail	Date	Response Date
Application AP3435SD	Received 11/03/2005	
Response to request for information	Request dated 10/05/2005	Response dated 11/08/2005
Permit determined	01/12/2005	
Variation notice UP3638MD issued	14/11/2006	

Superseded or Partially Superseded Licences/Authorisations/Consents relating to this installation

Holder	Reference Number	Date of Issue	Fully or Partially Superseded
MES Environmental Ltd	AX7571	14/07/1997	Fully

End of introductory Note

Variation Notice

Pollution Prevention and Control
(England and Wales) Regulations 2000



**ENVIRONMENT
AGENCY**

Variation Notice

Permit number (The Permit)

AP3435SD

Variation number

UP3638MD

The Environment Agency in exercise of its powers under Regulation 17 of the Pollution Prevention and Control (England and Wales) Regulations 2000 (S.I. 2000 No. 1973) (as amended), hereby varies the permit held by you **MES Environmental Ltd** ("the Operator"),

whose Registered Office (or Principle Office) is
**Crown Street,
Wolverhampton,
West Midlands, WV1 1QB**

Company registration number 2826294

to operate the installation at
**Dudley Energy from Waste Facility, Lister Road,
Dudley,
West Midlands, DY2 8JT.**

to the extent set out in Schedules 1 to 3 of this variation notice.

This notice shall take effect from 14 November 2006.

Signed

A handwritten signature in black ink, appearing to read 'RA Wynne', enclosed in a rectangular box.

RA Wynne

Authorised to sign on behalf of the Environment Agency

Date

14th November 2006

SCHEDULE 1 - CONDITIONS TO BE DELETED

1.1 None

SCHEDULE 2 - CONDITIONS TO BE AMENDED

2.1 The following condition shall be amended as follows:

2.2.1.3 The limits for emissions to air for the parameters and emission points set out in Table 2.2.2 shall not be exceeded except during a period of abnormal operation. During a period of abnormal operation, the limits for emissions to air for the parameters and emission points set out in Table 2.2.2 (a) shall not be exceeded.

Table 2.2.2 : Emission limits to air and monitoring during normal operation

Emission reference	point	Parameter	Limit (including Reference Period) ¹	Monitoring frequency	Monitoring method
A1,A2		Particulate matter	30 mg/m ³ ½-hr average	Continuous measurement	BS EN 13284-6 8
A1,A2		Particulate matter	10 mg/m ³ daily average	Continuous measurement	BS EN 13284-6 8
A1,A2		Particulate matter	20 mg/m ³ periodic over minimum 1-hour period	Bi-annual	BS EN 13284-
A1,A2		Total Organic Carbon (TOC)	20 mg/m ³ ½-hr average	Continuous measurement	BS EN 12619 8
A1,A2		Total Organic Carbon (TOC)	10 mg/m ³ daily average	Continuous measurement	BS EN 12619 8
A1,A2		Total Organic Carbon (TOC)	20 mg/m ³ periodic over minimum 1-hour period	Bi-annual	BS EN 12619
A1,A2		Hydrogen chloride	60 mg/m ³ ½-hr average	Continuous measurement	MCERTS certified instruments ^{7 8}
A1,A2		Hydrogen chloride	10 mg/m ³ daily average	Continuous measurement	MCERTS certified instruments ^{7 8}
A1,A2		Hydrogen chloride	30 mg/m ³	Bi-annual	BS EN 1911

Table 2.2.2 : Emission limits to air and monitoring during normal operation

Emission reference	point	Parameter	Limit (including Reference Period) ¹	Monitoring frequency	Monitoring method
			periodic over minimum 1-hour period		
A1,A2		Hydrogen fluoride	2 mg/m ³ periodic over minimum 1-hour period	Quarterly	USEPA Method 26/26A
A1,A2		Carbon monoxide	At least 95% of all measurements shall not exceed 150 mg/m ³ in any 24-hour period 10-minute average	Continuous measurement	ISO 12039 ^{4 8}
A1,A2		Carbon monoxide	50 mg/m ³ daily average	Continuous measurement	ISO 12039 ^{4 8}
A1,A2		Carbon monoxide	100 mg/m ³ periodic over minimum 4 hour period, data to be reported as 10-minute averages	Bi-annual	ISO 12039
A1,A2		Sulphur dioxide	200 mg/m ³ ½-hr average	Continuous measurement	BS 6069-4.4 ⁵
A1,A2		Sulphur dioxide	50 mg/m ³ daily average	Continuous measurement	BS 6069-4.4 ⁵
A1,A2		Sulphur dioxide	100 mg/m ³ periodic over minimum 4 hour period, data to be reported as ½ hour averages	Bi-annual	BS 6069-4.1 c alternative method if agreed in writing with the Agen
A1,A2		Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	400 mg/m ³ ½-hr average	Continuous measurement	ISO 10849 ^{5 8}
A1,A2		Oxides of nitrogen (NO and NO ₂ expressed as	200 mg/m ³ daily average	Continuous measurement	ISO 10849 ^{5 8}

Table 2.2.2 : Emission limits to air and monitoring during normal operation

Emission reference	point	Parameter	Limit (including Reference Period) ¹	Monitoring frequency	Monitoring method
		NO ₂)			
A1,A2		Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	350 mg/m ³ periodic over minimum 4 hour period, data to be reported as ½-hour averages	Bi-annual	ISO 10849 or BS ISO 11564
A1,A2		Cadmium & thallium and their compounds (total) ²	0.05 mg/m ³ periodic over minimum 30 minute, maximum 8 hour period	Quarterly	BS EN 14385
A1,A2		Mercury and its compounds ²	0.05 mg/m ³ periodic over minimum 30 minute, maximum 8 hour period	Quarterly	BS EN 13211
A1,A2		Sb, As, Pb, Cr, Co, Cu, Mn, Ni and V and their compounds (total) ²	0.5 mg/m ³ periodic over minimum 30 minute, maximum 8 hour period	Quarterly	BS EN 14385
A1,A2		Dioxins / furans (I-TEQ)	0.1 ng/m ³ periodic over minimum 6 hours, maximum 8 hour period ³	Bi-annual	BS EN 1948

Note 1: See Section 6 for reference conditions

Note 2: Metals include gaseous, vapour and solid phases as well as their compounds (expressed as the metal or the sum of the metals as specified). Sb, As, Pb, Cr, Co, Cu, Mn, Ni and V mean antimony, arsenic, lead, chromium, cobalt, copper, manganese, nickel and vanadium respectively.

Note 3: The I-TEQ sum of the equivalence factors to be reported as a range based on: All congeners less than the detection limit assumed to be zero as a minimum, and all congeners less than the detection limit assumed to be at the detection limit as a maximum.

Note 4: The Continuous Emission Monitors used shall be such that the values of the 95% confidence intervals of a single measured result at the daily emission limit value shall not exceed 10%. Valid 10-minute average values shall be determined within the effective operating time (excluding the start-up and shut-down periods) from the measured values after having subtracted this value of the confidence interval (10%). Where it is necessary to calibrate or maintain the monitor and this means that data is not available for a complete 10-minute period, the 10-minute average shall nonetheless be considered valid if measurements are available for a minimum of 7 minutes during the 10-minute period. (The number of 10-minute averages so validated shall not exceed 25 per day). Daily average values shall be determined as the average of all the valid 10-minute average values within a calendar day. The daily average value will be considered valid if no more than 15 10-minute average values in any day have been determined not to be valid. No more than ten daily average values per year shall be determined not to be valid.

Note 5: The Continuous Emission Monitors used shall be such that the values of the 95% confidence intervals of a single measured result at the daily emission limit value shall not exceed 20%. Valid half-hourly average values shall be determined within the effective operating time (excluding the start-up and shut-down periods) from the measured values after having subtracted this value of the confidence interval (20%). Where it is necessary to calibrate or maintain the monitor and this means that data is not available for a complete half-hour period, the half-hourly average shall nonetheless be considered valid if measurements are available for a minimum of 20 minutes during the half-hour period. (The number of half-hourly averages so validated shall not exceed 8 per day). Daily average values shall be determined as the average of all the valid half-hourly average values within a calendar day. The daily average value will be considered valid if no more than five half-hourly average values in any day have been determined not to be valid. No more than ten daily average values per year shall be determined not to be valid.

Note 6: As Note 5, except that the value of the confidence interval is 30% in place of 20%.

Note 7: As Note 5, except that the value of the confidence interval is 40% in place of 20%.

Note 8: MCERTS certification to the appropriate ranges and determinands is a demonstration of compliance to the applicable standards.

Note 9: The CEM shall be able to measure instantaneous values over the ranges that are to be expected during all operating conditions.

Table 2.2.2 (a) : Emission limits to air and monitoring during abnormal operating conditions

Emission reference	point	Parameter	Limit (including Reference Period) ¹	Monitoring frequency	Monitoring method
A1, A2		Particulate matter	150 mg/m ³ ½-hr average	Continuous measurement	BS EN 13824-2 ⁴² during abatement plant failure during failure of the continuous emission monitor
A1, A2		Total Organic Carbon (TOC)	20 mg/m ³ ½-hr average	Continuous measurement	BS EN 12619 ⁴² during abatement plant failure

during failure of the
continuous emission
monitor

A1, A2	Carbon monoxide	At least 95% of all measurements shall not exceed 150 mg/m ³ in any 24-hour period 10-minute average	Continuous measurement	ISO 12039 ⁴³ during abatement plant failure or during failure of the continuous emission monitor
--------	-----------------	--	------------------------	---

Note 1: See Section 6 for reference conditions

Note 2: The Continuous Emission Monitors used shall be such that the values of the 95% confidence intervals of a single measured result at the daily emission limit value shall not exceed 30%. Valid half-hourly average values shall be determined within the effective operating time (excluding the start-up and shut-down periods if no waste is being incinerated) from the measured values after having subtracted this value of the confidence interval (30%). Where it is necessary to calibrate or maintain the monitor and this means that data is not available for a complete half-hour period, the half-hourly average shall nonetheless be considered valid if measurements are available for a minimum of 20 minutes during the half-hour period. (The number of half-hourly averages so validated shall not exceed 8 per day).

Note 3: The Continuous Emission Monitors used shall be such that the values of the 95% confidence intervals of a single measured result at the daily emission limit value shall not exceed 10%. Valid 10-minute average values shall be determined within the effective operating time (excluding the start-up and shut-down periods if no waste is being incinerated) from the measured values after having subtracted this value of the confidence interval (10%). Where it is necessary to calibrate or maintain the monitor and this means that data is not available for a complete 10-minute period, the 10 minute average shall nonetheless be considered valid if measurements are available for a minimum of 7 minutes during the 10-minute period. (The number of 10-minute averages so validated shall not exceed 25 per day).

Note 4: MCERTS certification to the appropriate ranges and determinands is a demonstration of compliance to the applicable standards.

SCHEDULE 3 - CONDITIONS TO BE ADDED

3.1 None