

Permit Number : EPR/KP3808PN

Operator : Thalia AWRP ODC Limited

Facility : Allerton Waste Recovery Park

Form Number : Performance 1

Reporting of other performance indicators (Anaerobic Digestion Plant) for the year 2025

Parameter	Q1	Q2	Q3	Q4	Total
Total Waste Treated (tonnes)	1,371.53	1,426.55	1,790.35	1,292.23	5,880.66
Whole Digestate (tonnes)	1,631.74	1,310.84	2,138.75	1,770.93	6,852.26
Emergency Flare Operation (hours)	173.75	150	65.23	67.0	455.97
A4 CHP Engine Operation (hours)	7,727	17,228	6,128	25,936	57,019
A5 CHP Engine Operation (hours)	35,989	23,716	70,650	10,728	141,083
Biomethane Generated (M3)	113,067	108,058	165,659	72,749	459,533
Ferrous Chloride Used (ltr)	18,336.05	10,416.05	18,046.95	12,941.27	59,740.32
Electricity Generated (MWh)	223.96	262.04	455.51	284.32	1,225.83

Operator's comments:
Operator's comments:

Signed [Redacted Signature] Date 31/01/2026
(authorised to sign as representative of Thalia AWRP ODC Limited)