

Permit Number : EPR/KP3808PN
Facility : Allerton Waste Recovery Park

Operator : Thalia AWRP ODC Limited
Form Number : Air 7

Reporting of periodically monitored emissions to air for the period from January to December 2025 (2025A4)

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method	Result Date and Time ^[2]	Uncertainty ^[3]
A4	VOCs (as Carbon)	No limit applies	Measurement over minimum 1 hour.	107.02	EN 12619:2013	01/08/2025 09:55 - 10:55	8.27
A4	Oxides of Nitrogen (as NO ₂)	500 mg/m ³	Measurement over minimum 1 hour.	216.33	EN 14792	01/08/2025 09:55 - 10:55	10.09
A4	Carbon Monoxide	1400 mg/m ³	Measurement over minimum 1 hour.	824.30	EN 15058	01/08/2025 09:55 - 10:55	35.29
A4	Sulphur Dioxide	350 mg/m ³	Measurement over minimum 1 hour.	397.98	CEN/TS 17337	01/08/2025 09:55 - 10:55	24.42
A4	Gas Temperature	No limit applies oC	Measurement over minimum 1 hour.	464.8	-	01/08/2025 09:55 - 10:55	-
A4	Gas Velocity	No limit applies m/s	Measurement over minimum 1 hour.	23.0	EN 16911-1	01/08/2025 09:55 - 10:55	0.67

A4	Gas Water Vapour Content	No limit applies % v/v	Measurement over minimum 1 hour.	11.1	CEN/TS 17337	01/08/2025 09:55 - 10:55	0.6
A4	Gas Oxygen	No limit applies % v/v	Measurement over minimum 1 hour.	9.11 (Dry)	EN 14789	01/08/2025 09:55 - 10:55	0.26
A4	Gas Flow (Actual)	No limit applies m ³ /hr	Measurement over minimum 1 hour.	14971	EN 16911-1	01/08/2025 09:55 - 10:55	807

[1] The date and time of the sample that produced the result is given.

[2] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed: [REDACTED] Date: 31/01/2026

(authorised to sign as representative of Thalia AWRP ODC Limited)