

Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/DP3932RS
Name of operator	Evero Energy UK
Location of Facility	Hull – King George Dock
Time and date of the detection	1000 – 1300 01/01/2024

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection	
Date and time of the event	01/01/2024 @ 1000 - 1300 (3 hours)
Reference or description of the location of the event	Hull Biomass No1
Description of where any release into the environment took place	N/A
Substances(s) potentially released	N/A
Best estimate of the quantity or rate of release of substances	N/A
Measures taken, or intended to be taken, to stop any emission	Specialist advisor contacted and dialed in to site to rectify issue, investigation ongoing.
Description of the failure or accident.	Issues with CEMS monitoring displaying N/A.

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	N/A
Parameter(s)	N/A
Limit	N/A
Measured value and uncertainty	N/A
Date and time of monitoring	N/A


(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Measures taken, or intended to be taken, to stop the emission	N/A

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period
N/A	N/A

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	N/A
Substances(s) detected	N/A
Concentrations of substances detected	N/A
Date of monitoring/sampling	N/A

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	On 1 st of January whilst feeding solid fuel the CEMS readings gone to N/A between 10:00-13:00 and the readings recovered back by itself.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	CEMS system check list has carried out and no issues found. The service provider contacted to cross check the CEMS system on site.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	Investigation is still ongoing.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	Sinan Chetin
Post	Owners Engineer
Signature	
Date	02/01/2024